

### Builders requirements during construction stage:

1. External copper (13mm) mains water line for water switch control (elevation as indicated)
2. Weather proof GPO power point (elevation as indicated)
3. Down pipe/s located within 2m of tank with a minimum of 40sq/m roof catchment
4. Provisions for storm water line connection within 1m of tank
5. Flat level site. Base of tank must be fully supported across its entire area

